

City of Las Vegas Code and Interpretation

AMEND: 58

DATE: 10-6-09

CODE: 2006 IBC ☒ 2005 NEC ☐ Local Amendments ☐
 2006 IRC ☐ 2006 UMC ☐ POOL CODE ☐
 2006 IECC ☐ 2006 UPC ☐ MISC. ☐

CODE SECTION: 2006 IBC section 1405

TOPIC: Stone Veneer

PURPOSE/REASON: There is no current provision for the “adhered stone veneer” in both the 2006 IBC and the ACI 530-05/ASCE 5-05/TMS 402.

INTERPRETATION: **1405.9 Adhered masonry veneer.** Adhered masonry veneer shall comply with the applicable requirements in Section 1405.9.1 and Sections 6.1 and 6.3 of ACI 530/ASCE 5/TMS 402.

Adhered stone veneer units may use the prescriptive requirements for adhered masonry veneer in section 6.3.2 of ACI 530/ASCE 5/TMS 402. The stone veneer units shall not exceed 2-5/8 inch in specified thickness, 36 in. in any face dimension, nor more than 5 sq. ft. in total face area, and shall not weigh more than 15 lb per sq. ft.

Approved: Chris Knight, Building Official